

TGT DISPENSER HOSE TEST RESULTS DATE: 7-9-24

Serial Number:	24041454
Model Number:	T7203-12-8 CNG50
Customer Name:	GHEMM CONSTRUCTION
P.O. Number:	GHEM100123

HOSE 1

	SCALE	CUSTOMER	%ERROR
Test 1	11.650	11.684	.290
Test 2	11.170	11.182	.107
Test 3	11.500	11.518	.156
Test 4			
Test 5			
Test 6			
Average:	11.440	11.461	.183

HOSE 2

	SCALE	CUSTOMER	%ERROR
Test 1	11.520	11.486	.296
Test 2	11.850	11.848	.009
Test 3	11.860	11.832	.023
Test 4			
Test 5			
Test 6			
Average:	11.743	11.722	.178